

CHECKLIST FOR SELECTING
NEW EQUIPMENT OR NEW PROCESSES

Refer to specification 12100 for the definition of a new equipment and a new process.

Equipment:	IVS 130/135
Process:	Overlay Metrology in Fab 2
Responsible engineer:	Leo Schlegel/ Filip Rigole
Date:	24-10-2003

value/OK/
attach

1. Process requirements

- Technology and reliability requirements

List the physical parameters (thickness, resistivity, ...) describing the process

--

- Defect density requirements

Allowed machine added defects/wfr

5 /# > 0.1 micron
NA
Surfscan

Expected edge of wafer effects, Si utilization

Defect measurement method (KLA, Surfscan, ...)

2. Productivity

- Naked throughput
- Set-up/conditioning method and time
- Equipment monitoring method and time
- Process monitoring method and time

90 WPH

3. Availability

- Mean Wafer Between Cleans (MWBC)
- Mean Time Between Failure (MTBF)
- Mean Time To Repair (MTTR)
- Scheduled downtime
- Unscheduled downtime
- Wafer breakage :

1500 hours
4 hours
< 1 %
< 2 %

Typical frequency

10.000 #

Recovery procedure and time

0.5 hours

• Power dip

Sensitivity

Recovery procedure

0.5 hours

4. Safety aspects

Provide this information to the safety manager!

List the safety considerations that have to be made:

- Is the new tool CE compliant?
If not, who will do the CE marking?
- Do you have a signed copy of the CE certificate of conformity?
- Does the tool use ionising radiation?
- Does the equipment or process use chemicals or gases ?
If yes, what chemicals or gases ?
Is a recent MSDS or CPI card available of the chemicals or gases ?
- Does the tool contain or process liquid chemicals ?
If yes, is the tool made out of non-combustible material ?
Specify material:
If not or if flammable liquids are processed, does the tool have an automatic extinguishing system ?

Yes

No

No

No

5. Environmental aspects

Provide all this information to the environmental officer!

List all special environmental aspects that have to be considered:

- Does the equipment or process have an impact on the water usage?
Does the tool or process require DI-water? If yes, how much?
At the maximum capacity, what is the estimated quantity of waste water discharged?
List expected constituents in waste water
What's the expected pH of the waste water, acid or base?
- Does the equipment or process require gases?
What gases are needed?
At maximum capacity, what volume is needed of every gas in 1 yr?
Will the amount of stored gases change? If yes, how much will be added or removed?
Does the new tool or the tool where the new process is added have abatement (scrubber)?
- Does the equipment or process require liquid chemicals?

No

No

No

No

What liquid chemicals are needed?

At maximum capacity, what volume is needed of every liquid chemical in 1 yr?

At maximum capacity, estimate the quantity of each type of hazardous waste expected?

6. Fab Layout

Define the location of new equipment in Fab taking into account production, maintenance and facilities considerations

Litho Fab 2

7. Facility and bypack requirements

- List the required facilities:

Floorspace (measurement unit + operator console dimensions)

124.5 cm x
94 cm + 62.5
cm x 83.8 cm

Weight

453.5 kg

Vibration requirements :

- 2 microns peak to peak below 7 Hz
- 0.5 microns peak to peak 7 Hz to 150 Hz
- 2.0 microns peak to peak above 150 Hz

Similar to
stepper
vibration
system

Power requirements

115 V 50/60
Hz, 20 Amp,
single phase

Heat dissipation

NA

Exhaust

NA

DI-water

NA

City water

NA

Cooling water

NA

Vacuum

-24 to -27 in
HG, 0.8 cfm,
hose fitting ¼
in OD

Clean Compressed Air

90 psi 2cfm,
hose fitting ¼
inch

Chemical distribution system

NA

Gases

NA

Detection (gas, fire, leak)

NA

Drain

NA

Waste treatment

NA

- List the required bypack equipment

Vacuum pumps

NA

Heat exchangers

NA

Gas scrubbers/environmental requirements

NA

Transformers

8. Maintainability

- Spares: typical set (cost & lifetime) & common spares with existing equipment

31 K \$

- PM kits/swap kits: kit of parts required for a specific PM

- Documentation:

Spare parts list

Exploded mechanical drawings

Schematics (electronics, gas distribution, ...)

Maintenance manual procedures and frequency

- Support, possibility to have:

On-site support for set-up and maintenance

YES

Training at vendor site (process-operator / maintenance)

YES

Expert training from field experts on site

YES

9. Manufacturing integration

- Back-up scenarios from and to other equipment

YES

- Possibility of retrofitting other technologies

YES

- Reclaim procedure for monitor and conditioning wafers

NA

- Link with CIM infrastructure

Extra cost

- automation/LIS/data communication

- compatibility with other wafer sizes

4 to 8 inch

10. Cost

- Investments:

Equipment (incl. options)

Facilities

Safety/environment (precautions/adaptations)

Bypack

Spare kits

NA

31 k \$

- Expenses:

AMI Semiconductor Belgium BVBA

CHECKLIST FOR SELECTING NEW EQUIPMENT OR NEW PROCESSES - Standard form for descriptive spec

DS12100

STF-0153, Revision: 4.0

Revision date: 02-JUL-03

Page 4 of 5

Location: NA

Consumables / raw materials per waferpass

NA
NA

Cost of maintenance (PM + cleaning) (incl. bypack)

Maintenance contract

Monitoring and conditioning (wafers and consumables)

Cost of facilities (incl. waste treatment)

METROBOOST



1750 Halford Avenue, Suite 218
Santa Clara, CA 95051

February 27, 2004

License Grant

AMI Semiconductor, Belgium

MetroBoost, a California Company, hereby grants to AMI Semiconductor, Belgium a permanent, non-revocable, non-transferable **package** license to use Overlay Booster software version 2.61.

Package license entitles AMI Semiconductor to install and use Overlay Booster on two computer systems in its Belgium facilities; one system for real-time operation with IVS overlay metrology tool serial number ACVR256 manufactured by Soluris, Inc. of Concord, MA, and a second computer system for off-line data analysis.

This license is non-transferable except in the event of the sale of IVS system serial number ACVR256 or its relocation to another AMI Semiconductor facility.

The license remains valid for any future software update or upgrade that MetroBoost would provide free of charge during the period of one year from the date of installation.

This license grant is subject to other terms and conditions as stated in end-user software license agreement shipped with Overlay Booster software package. All other terms in EULA not specifically mentioned here shall remain valid.

Farid Askary
President
MetroBoost

Measurement System analysis Data Sheet

Measurement System :	IVS	Date :	25-Feb-04	Performed by :	Soluris
Measurement Program :	HIMQN180\OVERLAY Y direction				

Operation number :	3537	LSL :	-0.18	USL :	0.18
--------------------	------	-------	-------	-------	------

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	-0.0652	-0.0646	-0.0649	0.0006	-0.0686	-0.0581	-0.0671	0.0105	-0.0625	-0.0638	-0.0681	0.0056
2	-0.0287	-0.0249	-0.026	0.0038	-0.0264	-0.028	-0.0286	0.0022	-0.0285	-0.0239	-0.0247	0.0046
3	-0.0396	-0.0398	-0.0406	0.001	-0.0396	-0.0396	-0.0427	0.0031	-0.0408	-0.0374	-0.039	0.0034
4	-0.0159	-0.0192	-0.0157	0.0035	-0.0163	-0.0158	-0.0178	0.002	-0.0148	-0.0177	-0.0165	0.0029
5	-0.0367	-0.0398	-0.0362	0.0036	-0.0353	-0.0376	-0.0305	0.0071	-0.0345	-0.0341	-0.0344	0.0004
6	-0.0127	-0.0089	-0.0138	0.0049	-0.0138	-0.0117	-0.0113	0.0025	-0.0162	-0.0133	-0.0135	0.0029
7	-0.0223	-0.0222	-0.0249	0.0027	-0.0211	-0.0229	-0.0243	0.0032	-0.026	-0.0239	-0.0228	0.0032
8	-0.003	-0.0006	0.0005	0.0035	-0.0026	-0.0007	-0.0032	0.0025	-0.0014	-0.0031	0.0005	0.0036
9	-0.0239	-0.0248	-0.0247	0.0009	-0.0253	-0.0231	-0.0249	0.0022	-0.0254	-0.0274	-0.0248	0.0026
10	0.0097	0.0113	0.0108	0.0016	0.0077	0.0115	0.0101	0.0038	0.0104	0.0097	0.0094	0.001
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	-0.238	-0.234	-0.236	0.026	-0.241	-0.226	-0.240	0.039	-0.240	-0.235	-0.234	0.030
N	10			N	10			N	10			
Trials	2			Oper.	3							

T1	-0.238
T2	-0.234
T3	-0.236
SUM	-0.707
Xav	-0.024
Rav	0.003

T1	-0.241
T2	-0.226
T3	-0.240
SUM	-0.708
Xav	-0.024
Rav	0.004

T1	-0.240
T2	-0.235
T3	-0.234
SUM	-0.709
Xav	-0.024
Rav	0.003

Raverage	0.003
UCLrange	0.010

d ₂	1.128
D2s	1.910
D4	3.267

Xmax	-0.024	
Xmin	-0.024	
Xdelta	0.000	0.000

Repeatability :	0.017
Reproducibility :	0.000
R&R :	0.017
R&R % :	4.70

Variation in measurement when one operator uses the same instrument and measures the same parts

Variation in measurement due to different operators or instruments, measuring the same parts

Total variation due to repeatability and reproducibility

Percent of the tolerance that is taken up by measurement error

Measurement System analysis Data Sheet

Measurement System :	IVS	Date :	25-Feb-04	Performed by :	Soluris
Measurement Program :	HIMQN\180\OVERLAY X direction				

Operation number :	3537	LSL :	-0.18	USL :	0.18
--------------------	------	-------	-------	-------	------

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	0.0228	0.0215	0.0197	0.0031	0.0224	0.0201	0.0234	0.0033	0.0216	0.0224	0.021	0.0014
2	0.0547	0.0527	0.056	0.0033	0.0536	0.0555	0.053	0.0025	0.0538	0.0556	0.0534	0.0022
3	0.0292	0.0275	0.0296	0.0021	0.0284	0.0279	0.0298	0.0019	0.0284	0.0273	0.0283	0.0011
4	0.0567	0.0569	0.0571	0.0004	0.0547	0.0565	0.0563	0.0018	0.0562	0.0568	0.0555	0.0013
5	0.0442	0.0424	0.0394	0.0048	0.0409	0.0418	0.0411	0.0009	0.0429	0.0412	0.0396	0.0033
6	0.0525	0.0496	0.0498	0.0029	0.052	0.0496	0.0502	0.0024	0.0525	0.0498	0.0524	0.0027
7	0.007	0.0084	0.0073	0.0014	0.0063	0.0074	0.0078	0.0015	0.0081	0.0081	0.0076	0.0005
8	0.0373	0.0377	0.0365	0.0012	0.0361	0.036	0.0358	0.0003	0.0369	0.0355	0.0343	0.0026
9	0.0227	0.0238	0.0241	0.0014	0.024	0.0234	0.0232	0.0008	0.0241	0.0238	0.0225	0.0016
10	0.0157	0.0163	0.0154	0.0009	0.0168	0.0147	0.0168	0.0021	0.0155	0.0162	0.0157	0.0007
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	0.343	0.337	0.335	0.022	0.335	0.333	0.337	0.018	0.340	0.337	0.330	0.017
N	10			N	10			N	10			
Trials	2			Oper.	3							

T1	0.343
T2	0.337
T3	0.335
SUM	1.015
Xav	0.034
Rav	0.002

T1	0.335
T2	0.333
T3	0.337
SUM	1.006
Xav	0.034
Rav	0.002

T1	0.340
T2	0.337
T3	0.330
SUM	1.007
Xav	0.034
Rav	0.002

Raverage	0.002
UCLrange	0.006

d ₂	1.128
D2s	1.910
D4	3.267

Xmax	0.034	
Xmin	0.034	
Xdelta	0.000	0.000

Repeatability :	0.010
Reproducibility :	0.000
R&R :	0.010
R&R % :	2.78

Variation in measurement when one operator uses the same instrument and measures the same parts

Variation in measurement due to different operators or instruments, measuring the same parts

Total variation due to repeatability and reproducibility

Percent of the tolerance that is taken up by measurement error

Measurement System analysis Data Sheet	
--	--

Measurement System :	IVS	Date :	25-Feb-04	Performed by :	Soluris
----------------------	-----	--------	-----------	----------------	---------

Measurement Program :	CECFN\140\OVERLAY Y direction
-----------------------	-------------------------------

Operation number :	3534	LSL :	-0.15	USL :	0.15
--------------------	------	-------	-------	-------	------

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	-0.0199	-0.0216	-0.0197	0.0019	-0.0216	-0.021	-0.0217	0.0007	-0.0219	-0.0224	-0.0223	0.0005
2	-0.0121	-0.0126	-0.0135	0.0014	-0.0136	-0.014	-0.012	0.002	-0.0138	-0.0133	-0.0135	0.0005
3	-0.015	-0.0164	-0.0169	0.0019	-0.0174	-0.0157	-0.0167	0.0017	-0.0162	-0.0175	-0.017	0.0013
4	-0.0345	-0.0342	-0.0343	0.0003	-0.0332	-0.0347	-0.0334	0.0015	-0.0345	-0.0341	-0.0339	0.0006
5	-0.0327	-0.0326	-0.0335	0.0009	-0.034	-0.0325	-0.0336	0.0015	-0.0328	-0.0339	-0.033	0.0011
6	-0.0248	-0.0249	-0.0249	1E-04	-0.0258	-0.0261	-0.0255	0.0006	-0.0255	-0.0257	-0.0255	0.0002
7	-0.0149	-0.0159	-0.0165	0.0016	-0.0163	-0.0164	-0.0165	0.0002	-0.0165	-0.0169	-0.0165	0.0004
8	-0.0067	-0.0069	-0.0069	0.0002	-0.0075	-0.0072	-0.0072	0.0003	-0.008	-0.0075	-0.0082	0.0007
9	-0.017	-0.0158	-0.0164	0.0012	-0.0174	-0.0163	-0.0175	0.0012	-0.0173	-0.018	-0.0177	0.0007
10	-0.0307	-0.0308	-0.0307	1E-04	-0.0315	-0.0311	-0.0316	0.0005	-0.0295	-0.0313	-0.0309	0.0018
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	-0.208	-0.212	-0.213	0.010	-0.218	-0.215	-0.216	0.010	-0.216	-0.221	-0.219	0.008
--------	--------	--------	--------	-------	--------	--------	--------	-------	--------	--------	--------	-------

N	10		N	10
Trials	2		Oper.	3

T1	-0.208
T2	-0.212
T3	-0.213
SUM	-0.633
Xav	-0.021
Rav	0.001

T1	-0.218
T2	-0.215
T3	-0.216
SUM	-0.649
Xav	-0.022
Rav	0.001

T1	-0.216
T2	-0.221
T3	-0.219
SUM	-0.655
Xav	-0.022
Rav	0.001

Raverage	0.001
UCLrange	0.003

d_2^*	1.128
D2s	1.910
D4	3.267

Xmax	-0.021	
Xmin	-0.022	
Xdelta	0.001	0.000

Repeatability :	0.005
-----------------	--------------

Variation in measurement when one operator uses the same instrument and measures the same parts

Reproducibility :	0.002
-------------------	--------------

Variation in measurement due to different operators or instruments, measuring the same parts

R&R :	0.005
-------	-------

Total variation due to repeatability and reproducibility

R&R % :	1.76
---------	------

Percent of the tolerance that is taken up by measurement error

Measurement System analysis Data Sheet

Measurement System :	IVS	Date :	25-Feb-04	Performed by :	Soluris
Measurement Program :	CECFN\140\OVERLAY X direction				

Operation number :	3534	LSL :	-0.15	USL :	0.15
--------------------	------	-------	-------	-------	------

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	0.0882	0.0878	0.0869	0.0013	0.087	0.0879	0.0872	0.0009	0.0872	0.0866	0.0869	0.0006
2	0.1071	0.1076	0.1073	0.0005	0.1072	0.1073	0.1081	0.0009	0.1072	0.1073	0.1076	0.0004
3	0.0722	0.0716	0.0724	0.0008	0.0729	0.0722	0.0724	0.0007	0.0727	0.0728	0.072	0.0008
4	0.0691	0.0695	0.0695	0.0004	0.0704	0.07	0.0704	0.0004	0.0692	0.0693	0.0687	0.0006
5	0.0915	0.0897	0.091	0.0018	0.0903	0.0907	0.0916	0.0013	0.0905	0.0892	0.0917	0.0025
6	0.0859	0.0856	0.0858	0.0003	0.0864	0.0858	0.0849	0.0015	0.0856	0.0862	0.0862	0.0006
7	0.1253	0.1258	0.1262	0.0009	0.1263	0.1247	0.1258	0.0016	0.1246	0.1254	0.1249	0.0008
8	0.089	0.0888	0.0892	0.0004	0.0892	0.0886	0.0892	0.0006	0.0887	0.0888	0.0897	0.001
9	0.0628	0.0632	0.0635	0.0007	0.0636	0.0628	0.0632	0.0008	0.0623	0.0642	0.0625	0.0019
10	0.0592	0.0589	0.0594	0.0005	0.0591	0.0595	0.0597	0.0006	0.0593	0.0593	0.0599	0.0006
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	0.850	0.849	0.851	0.008	0.852	0.850	0.853	0.009	0.847	0.849	0.850	0.010
N	10			N	10			N	10			
Trials	2			Oper.	3							

T1	0.850
T2	0.849
T3	0.851
SUM	2.550
Xav	0.085
Rav	0.001

T1	0.852
T2	0.850
T3	0.853
SUM	2.554
Xav	0.085
Rav	0.001

T1	0.847
T2	0.849
T3	0.850
SUM	2.547
Xav	0.085
Rav	0.001

Raverage	0.001
UCLrange	0.003

d ₂	1.128
D2s	1.910
D4	3.267

Xmax	0.085	
Xmin	0.085	
Xdelta	0.000	0.000

Repeatability :	0.005
Reproducibility :	0.000
R&R :	0.005
R&R % :	1.58

Variation in measurement when one operator uses the same instrument and measures the same parts

Variation in measurement due to different operators or instruments, measuring the same parts

Total variation due to repeatability and reproducibility

Percent of the tolerance that is taken up by measurement error

Measurement System analysis Data Sheet

Measurement System :	IVS	Date :	25-Feb-04	Performed by :	Soluris
Measurement Program :	CECFN\090\OVERLAY Y direction				

Operation number :	3527	LSL :	-0.1	USL :	0.1
--------------------	------	-------	------	-------	-----

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	-0.0204	-0.0214	-0.021	0.001	-0.0216	-0.0213	-0.0205	0.0011	-0.0223	-0.02	-0.0207	0.0023
2	-0.013	-0.0124	-0.0128	0.0006	-0.0121	-0.0129	-0.0127	0.0008	-0.0136	-0.0116	-0.0115	0.0021
3	0.0091	0.0081	0.0068	0.0023	0.0079	0.009	0.0082	0.0011	0.0086	0.0074	0.0082	0.0012
4	0.0037	0.0039	0.005	0.0013	0.0051	0.0045	0.0048	0.0006	0.0046	0.0043	0.0042	0.0004
5	-0.0253	-0.0255	-0.0249	0.0006	-0.0263	-0.0258	-0.0289	0.0031	-0.0262	-0.0255	-0.0275	0.002
6	-0.0028	-0.0007	-0.0008	0.0021	-0.0006	-0.0023	-0.0021	0.0017	-0.0011	-0.0018	-0.0011	0.0007
7	-0.0406	-0.0399	-0.0424	0.0025	-0.0398	-0.0407	-0.0413	0.0015	-0.042	-0.0409	-0.0406	0.0014
8	-0.029	-0.0279	-0.0284	0.0011	-0.0281	-0.0289	-0.0278	0.0011	-0.0299	-0.0283	-0.028	0.0019
9	-0.0111	-0.008	-0.0105	0.0031	-0.0082	-0.008	-0.0086	0.0006	-0.0085	-0.0094	-0.0085	0.0009
10	-0.0097	-0.0101	-0.0095	0.0006	-0.0105	-0.01	-0.0092	0.0013	-0.0106	-0.0088	-0.0107	0.0019
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	-0.139	-0.134	-0.139	0.015	-0.134	-0.136	-0.138	0.013	-0.141	-0.135	-0.136	0.015
N	10			N	10			N	10			
Trials	2			Oper.	3							

T1	-0.139
T2	-0.134
T3	-0.139
SUM	-0.412
Xav	-0.014
Rav	0.002

T1	-0.134
T2	-0.136
T3	-0.138
SUM	-0.409
Xav	-0.014
Rav	0.001

T1	-0.141
T2	-0.135
T3	-0.136
SUM	-0.412
Xav	-0.014
Rav	0.001

Raverage	0.001
UCLrange	0.005

d ₂	1.128
D2s	1.910
D4	3.267

Xmax	-0.014	
Xmin	-0.014	
Xdelta	0.000	0.000

Repeatability :	0.008
-----------------	-------

Variation in measurement when one operator uses the same instrument and measures the same parts

Reproducibility :	0.000
-------------------	-------

Variation in measurement due to different operators or instruments, measuring the same parts

R&R :	0.008
-------	-------

Total variation due to repeatability and reproducibility

R&R % :	3.80
---------	------

Percent of the tolerance that is taken up by measurement error

Measurement System analysis Data Sheet

Measurement System :	IVS	Date :	25-Feb-04	Performed by :	Soluris
Measurement Program :	CECFN\090\OVERLAY X direction				

Operation number :	3527	LSL :	-0.1	USL :	0.1
--------------------	------	-------	------	-------	-----

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	-0.0479	-0.0499	-0.05	0.0021	-0.0501	-0.0502	-0.0491	0.0011	-0.0497	-0.0494	-0.0498	0.0004
2	0.0401	0.0407	0.0413	0.0012	0.0407	0.0414	0.0398	0.0016	0.0407	0.0396	0.0392	0.0015
3	-0.0504	-0.0499	-0.05	0.0005	-0.0529	-0.0533	-0.0507	0.0026	-0.0511	-0.0507	-0.0508	0.0004
4	0.0525	0.0529	0.0524	0.0005	0.0531	0.0519	0.053	0.0012	0.052	0.0527	0.0531	0.0011
5	-0.0558	-0.0555	-0.0548	0.001	-0.0551	-0.0568	-0.0548	0.002	-0.0557	-0.0557	-0.0577	0.002
6	0.0694	0.0693	0.0695	0.0002	0.0685	0.069	0.0697	0.0012	0.0697	0.0702	0.07	0.0005
7	-0.0287	-0.0289	-0.0281	0.0008	-0.0286	-0.0281	-0.0296	0.0015	-0.0288	-0.0295	-0.0294	0.0007
8	0.0611	0.0627	0.0617	0.0016	0.0619	0.0617	0.0624	0.0007	0.0618	0.0628	0.0624	0.001
9	-0.0197	-0.0208	-0.0208	0.0011	-0.0205	-0.0208	-0.0211	0.0006	-0.0207	-0.0197	-0.0205	0.001
10	0.073	0.0708	0.0714	0.0022	0.0732	0.0727	0.0719	0.0013	0.0721	0.0726	0.0733	0.0012
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	0.094	0.091	0.093	0.011	0.090	0.088	0.092	0.014	0.090	0.093	0.090	0.010
N	10			N	10			N	10			
Trials	2			Oper.	3							

T1	0.094
T2	0.091
T3	0.093
SUM	0.278
Xav	0.009
Rav	0.001

T1	0.090
T2	0.088
T3	0.092
SUM	0.269
Xav	0.009
Rav	0.001

T1	0.090
T2	0.093
T3	0.090
SUM	0.273
Xav	0.009
Rav	0.001

Raverage	0.001
UCLrange	0.004

d ₂	1.128
D2s	1.910
D4	3.267

Xmax	0.009	
Xmin	0.009	
Xdelta	0.000	0.000

Repeatability :	0.006
Reproducibility :	0.000
R&R :	0.006
R&R % :	3.09


Variation in measurement when one operator uses the same instrument and measures the same parts

Variation in measurement due to different operators or instruments, measuring the same parts

Total variation due to repeatability and reproducibility

Percent of the tolerance that is taken up by measurement error

IVS 130 Networking configuration



- IVS computer will send data file to real time computer to get Overlay Booster analysis
- IVS job plans and data files can be stored on real time computer : from the office you can open, analyze data files from engineer computer

February 10, 2004

SOLURIS



IVS 130

Factory Qualification Test

Prepared For:

Leo Schlegel

Sr. Process Engineer

AMI Semiconductor Belgium BVBA

Tel: +32 55 332 464

Fax: +32 55 332 223

leo_schlegel@amis.com

Prepared By:

John Podlesny

Applications Group Leader

Soluris Inc.

Tel: (978)815-5904

Fax: (480)897-0503

JPodlesny@soluris.com

Revision 1.0

SOLURIS

Table of Contents

I.WAFER HANDLING	3
II.METROLOGY	3
A. OVERLAY REGISTRATION TEST – PRECISION	3
B. OVERLAY REGISTRATION TEST – TOOL INDUCED SHIFT:	4
C. CRITICAL DIMENSION TEST - PRECISION	4
III.FOCUS AND PATTERN RECOGNITION:	5
IV.SYSTEM THROUGHPUT TEST:	6
A. THROUGHPUT TEST - 5 DIE/WAFER; 1 SITE/DIE:	6
V.PARTICULE COUNT:	6
VI.SOFTWARE	7
VII.MISCELLANEOUS:	8
VIII.SYSTEM FACORY ACCEPTANCE TESTING	8

SOLURIS

I. Wafer Handling

The IVS 130 will transfer 1500 monitor wafers in a dynamic mode including: transferring wafers to the pre-aligner; finding the flat/notch; transferring the wafers to the stage; and replacing the wafers in the cassette. This test shall be performed allowing for no more than one failure. A failure will result with a handler system error code in the printed data. This test will be divided into three sessions with 500 wafers per cassette platform (3 x 500 = 1500 total wafers).

CASSETTE PLATFORM	WAFERS CYCLED	LOAD ANGLE MIN	LOAD ANGLE MAX	LOAD ANGLE RANGE	NUMBER OF FAILURES	SPEC. (percent)
A	500	0.0450	0.2500	0.2050	0	99.0
B	500	-0.0410	0.2030	0.2440	0	99.0
C	500	-0.0640	0.1350	0.1990	0	99.0

II. Metrology

A. Overlay Registration Test – Precision

The precision of the system overlay registration performance shall be demonstrated on four standard production layers as described below. This test will be performed using optimized job plans. These wafers will be selected from Customer standard production lots. One mutually acceptable wafer shall be provided for each of the registration test layers.

Test Procedure: This test shall include measuring box-in-box, box-in-frame, or bar-in-bar overlay registration marks on 5 fields, 2 sites per field, at agreed to locations across the wafers described. It is assumed the targets will be equivalent to IVS' standard specification for box-in-box feature dimensions which are: 10 microns for the inner box and 20 microns for the outer box. As a general rule, the inner edge of the outer box should have a dimension which is twice that of the inner box dimension. Ten dynamic mode measurements (wafer load/unload between measurements) for each site shall be taken.

Specification: Pooled 3 Sigma Standard Deviation ≤ 2.5 nanometers for each wafer. Worst Case 3 Sigma Standard Deviation ≤ 6.0 nanometers for any given site. It should be noted that system performance may be affected by: extremely grainy films, targets distorted by CMP, film thickness variations and edge slope variations more than +/-10% in the targeted measurement area

SOLURIS

SLOT	WAFER ID	X – POOLED 3 σ in nm	Y – POOLED 3 σ in nm	SPEC. 3 σ in nm
1	APSC N/10vs5/rg			2.5
3	HIMQ N/180vs160/rg			2.5
5	CECF N/90vs60/rg			2.5
7	CECF N/140vs130/rg			2.5

B. Overlay Registration Test – Tool Induced Shift:

The system Tool Induced Shift (TIS) performance shall be demonstrated on the wafers from Section II.A.

Test Procedure: This test shall include measuring ten box-in-box overlay registration marks at agreed to locations across the wafer described. Ten static mode measurements for each site shall be taken. This test shall be run after IVS has performed the RG180 calibration process. TIS shall be calculated as follows: ((reg. measurement means for x, y axes with the notch or flat at 0 degrees) + (reg. measurement means for x, y axes with the **notch or** flat at 180 degrees))/2.

Specification: Mean Value of TIS (for both x and y axis) $\leq \pm 2$ nanometers
Worst Case Value of TIS (for both x and y axis) $\leq \pm 5$ nanometers

It should be noted that system performance may be affected by: extremely grainy films, targets distorted by CMP, film thickness variations and edge slope variations more than +/-10% in the targeted measurement area.

SLOT	WAFER ID	X AXIS TIS Average In nm	Y AXIS TIS Average In nm	SPEC. In nm
1	APSC N/10vs5/rg			± 2.00
3	HIMQ N/180vs160/rg			± 2.00
5	CECF N/60vs90/rg			± 2.00
7	CECF N/140vs130/rg			± 2.00

C. Critical Dimension Test - Precision

The precision of the system CD performance shall be demonstrated on four standard production layers as described below. One mutually acceptable wafer shall be provided for each of the four CD test layers defined. This specification addresses the 100x lens. Specifications for measurements using the 5x, 20x, 50, and 150x lenses will be quoted upon request.

Test Procedure: This test shall include measuring an agreed to nominal greater than or equal to 1.0 micron line at five CD sites across the wafers described. Ten dynamic mode measurements (wafer load/unload between measurements) for each site shall be taken.

Specification: Pooled 3 Sigma Standard Deviation ≤ 12 nanometers, or 1%, whichever is greater.

SOLURIS

SLOT	WAFER ID	POOLED 3 σ in nm	SPEC. 3 σ in nm
19	J454_O/125/CD	4.87	13.9
21	CORA_O/160M/CD	2.18	12.0
23	AGDA_N/9/CD	11.20	12.0
25	CORA_O/160R/CD	9.29	14.4

D. Pitch – Accuracy and Precision

The accuracy and precision of the tool shall be demonstrated on at least 1 VLSI wafer. Pitch measurements shall be made on 2 and 4 μ m targets.

Test Procedure: This test shall include measuring a VLSI certified pitch standard. The 2.0 and 4.0 μ m pitch targets shall be measured ten times dynamically, and their mean and precision values shall be taken.

SLOT	WAFER ID	PITCH in μ m	POOLED 3 σ in nm
16	LWS-2620 2 μ m	1.996	2.4
16	LWS-2620 4 μ m	3.981	3.3
25	LWS-2620 2 μ m	1.985	1.5
25	LWS-2620 4 μ m	3.987	2.7
19	LWS-2620 2 μ m	1.992	3.0
19	LWS-2620 4 μ m	3.981	3.0

III. Focus and Pattern Recognition:

The IVS 130 shall be able to focus and perform the pattern recognition function successfully 98% of the time on the production wafer layers defined in Section II.A and II.C. If a failure occurs, the system must continue to process wafers unassisted. A failure will result with a focus or pattern recognition system error code in the data. No wafers with known pattern defects shall be used in the testing.

SLOT	WAFER ID	NUMBER OF SITE LOCATES	PATTERN RECOGNITION (percent)	SPEC. (percent)
1	APSC_N/10vs5/rg	10		98.0
3	HIMQ_N/180vs160/rg	10		98.0
5	CECF_N/60vs90/rg	10		98.0
7	CECF_N/140vs130/rg	10		98.0
19	J454_O/125/CD	5	100.0	98.0
21	CORA_O/160M/CD	5	100.0	98.0
23	AGDA_N/9/CD	5	100.0	98.0
25	CORA_O/160R/CD	5	100.0	98.0

SOLURIS

IV. System Throughput Test:

A. Throughput Test - 5 die/wafer; 1 site/die:

System throughput shall include measuring one registration feature in the x and y axes at each of five sites per wafer. The test will measure one layer type and will use a single job. IVS' Edge Focus method along with the grey scale pattern recognition method shall be used. System throughput shall be measured starting at the beginning of the vacuum sensing of the first wafer on the stage and ending with the tenth wafer from the stage at vacuum sense off. In the event that 10 wafers are not provided, one wafer shall be measured 10 times, and throughput shall be measured starting at the beginning of the vacuum sensing of the wafer on the stage and ending when the wafer is taken from the stage and the vacuum sensing turns off.

Specification: The system shall measure 90 wafers per hour performed on ten wafers using one of the standard production layers identified in section II.A.

RUN	WAFER ID	Wafer Time In Sec.	Throughput In WPH	SPEC. In WPH
1		40	90.0	
2		39	92.3	
3		40	90.0	
4		40	90.0	
5		39	92.3	
6		41	87.8	
7		39	92.3	
8		41	87.8	
9		40	90.0	
10		40	90.0	
Average:			90.3	90

V. Particle Count:

The IVS 130 shall not add more than 10 particles, per pass per eight inch wafer, 0.1 microns in size or larger. Five test wafers and five control wafers shall be measured for particulates before the test. The test wafers shall: transfer from the cassette to the flat finder; transfer the wafer to the stage; rotate objectives; and then be replaced in the cassette. The control wafers shall be set on top of the IVS 130 to establish a background particulate level. This procedure shall be repeated five times for each wafer. The test and control wafers shall be particulate tested after completion of the ten passes. The environment around the system shall be isolated and/or be controlled for this test.

Particles per wafer, per pass, shall defined as:

SOLURIS

$PWP = W \times n \times (PG_{\text{test}} - PG_{\text{control}})$
PWP = Particles per Wafer per Pass
W = Number of wafers measured
n = Number of passes through the system
PG = (Particles measured after the test) - (Particles measured before the test)

It is expected that the particle test will be run within a reasonable period of time in comparison to when the rest of the system acceptance tests are run.

SLOT	WAFER ID	CHANGE – CONTROL WAFERS	AVERAGE PARTICLE COUNT	SPEC. (Particles)
1	Sample			≤10.0
2	Control			
3	Sample			≤10.0
4	Control			
5	Sample			≤10.0
6	Control			
7	Sample			≤10.0
8	Control			
9	Sample			≤10.0
10	Control			

To be performed at installation only

VI. Software

The system software will operate according to the description in the User's Manual. Any software releases will be accompanied by a set of Release Notes which will detail the changes to the system software and operations. This documentation will be provided in a format similar to the User's Manual which will allow for the material to be added as an addendum to the manual.

In the event the optional GEM communications package is purchased, the package shall function as described in the SEMI E30-94 document excluding the limits monitoring capability. Soluris will quote modifications to this package upon request.

In the event the optional SECS II communications package is purchased, the package shall function in accordance with Soluris' specifications.

In the event the Metroboost Overlay Booster Stepper Optimization Package is purchased, the package shall provide the functionality associated with v2.38 and higher, and will be in accordance with the Overlay Booster User Guide. Soluris will quote additions and modifications to this package upon request.

SOLURIS

In the event the optional Monolith Stepper Analysis package is purchased with real-time capability, the package shall function in accordance with the NVS Monolith manual. Soluris will quote additions and modifications to this package upon request.

VII. Miscellaneous:

The above acceptance test specification is subject to Soluris' pre-examination of the wafers that will be used for this test. It should be noted that system performance may be affected by: extremely grainy films, film thickness variations and edge slope variations more than +/-10% in the targeted measurement area. After Soluris has reviewed the wafers submitted for the Acceptance Test, a final commitment will be made concerning the actual system performance specifications.

The system shall be considered accepted by **AMIS**, and warranty shall begin: 1. After successful completion of the agreed-to acceptance test, and sign-off by **AMIS** OR upon beneficial use by **AMIS**. Beneficial use is defined as using the system for something other than testing, including but not limited to pilot production, engineering test lots, production, and device prototyping. In cases where the facility and/or utilities are not ready as committed by customer, customer is liable for revisit expenses.

The equipment shall be available and fully operational 95% of the time. A call reporting that the equipment is down must be made to Soluris before system down time can begin. Soluris Customer Service provides on-site technical support during normal business hours, which are Monday through Friday, 8:30 am to 5:30 PM local time (exclusive of Soluris Holidays) during the Warranty period. Soluris also provides Answering Service support 7 days per week, 24 hours per day. This service will route your incoming calls accordingly. Wafers for the above tests shall be provided to Soluris as soon as possible although no later than six weeks prior to the scheduled shipment date. These wafers shall be used for the factory acceptance and the final acceptance testing at the customer facility.

VIII. System Factory Acceptance Testing

The IVS 130 has successfully demonstrated the capability expected by the customer for Source Acceptance. Shipment from Soluris is authorized.

SOLURIS

John Podlesny

Applications Group Leader

Soluris Inc.

Date

Leo Schlegel

Sr. Process Engineer

AMI Semiconductor Belgium BVBA

Date

February 27, 2004

SOLURIS



IVS 130

On site Qualification Test

Prepared For:

Leo Schlegel

Sr. Process Engineer

AMI Semiconductor Belgium BVBA

Tel: +32 55 332 464

Fax: +32 55 332 223

leo_schlegel@amis.com

Prepared By:

Marc Poulingue

Applications Engineer

Soluris Inc.

Tel: +33 (0)6 20 17 15 69

Fax: + 1 978 287 0138

mpoulingue@soluris.com

SOLURIS

Table of Contents

I.WAFER HANDLING	3
II.METROLOGY	3
A. OVERLAY REGISTRATION TEST – PRECISION	3
B. OVERLAY REGISTRATION TEST – TOOL INDUCED SHIFT:	4
C. CRITICAL DIMENSION TEST - PRECISION	4
III.FOCUS AND PATTERN RECOGNITION:	5
IV.SYSTEM THROUGHPUT TEST:	5
A. THROUGHPUT TEST - 5 DIE/WAFER; 1 SITE/DIE:	5
V.PARTICULE COUNT:	6
VI.SOFTWARE	7
VII.MISCELLANEOUS:	8
VIII.SYSTEM FACORY ACCEPTANCE TESTING	9

SOLURIS

I. Wafer Handling

The IVS 130 will transfer 1500 monitor wafers in a dynamic mode including: transferring wafers to the pre-aligner; finding the flat/notch; transferring the wafers to the stage; and replacing the wafers in the cassette. This test shall be performed allowing for no more than one failure. A failure will result with a handler system error code in the printed data. This test will be divided into three sessions with 500 wafers per cassette platform (3 x 500 = 1500 total wafers).

CASSETTE PLATFORM	WAFERS CYCLED	LOAD ANGLE MIN	LOAD ANGLE MAX	LOAD ANGLE RANGE	NUMBER OF FAILURES	SPEC. (percent)
A	500	0.1090	0.2740	0.1650	0	99.0
B	500	0.0510	0.2260	0.1750	0	99.0
C	500	0.0500	0.2210	0.1710	0	99.0

II. Metrology

A. Overlay Registration Test – Precision

The precision of the system overlay registration performance shall be demonstrated on four standard production layers as described below. This test will be performed using optimized job plans. These wafers will be selected from Customer standard production lots. One mutually acceptable wafer shall be provided for each of the registration test layers.

Test Procedure: This test shall include measuring box-in-box, box-in-frame, or bar-in-bar overlay registration marks on 5 fields, 2 sites per field, at agreed to locations across the wafers described. It is assumed the targets will be equivalent to IVS' standard specification for box-in-box feature dimensions which are: 10 microns for the inner box and 20 microns for the outer box. As a general rule, the inner edge of the outer box should have a dimension which is twice that of the inner box dimension. Ten dynamic mode measurements (wafer load/unload between measurements) for each site shall be taken.

Specification: Pooled 3 Sigma Standard Deviation ≤ 2.5 nanometers for each wafer. Worst Case 3 Sigma Standard Deviation ≤ 6.0 nanometers for any given site. It should be noted that system performance may be affected by: extremely grainy films, targets distorted by CMP, film thickness variations and edge slope variations more than +/-10% in the targeted measurement area

SOLURIS

SLOT	WAFER ID	X – POOLED 3 σ in nm	Y – POOLED 3 σ in nm	SPEC. 3 σ in nm
1	APSC N/10vs5/rg	1.9	3.2	4.0
3	HIMQ N/180vs160/rg	3.1	5.3	6.0
5	CECF N/90vs60/rg	2.0	2.3	2.5
7	CECF N/140vs130/rg	1.6	1.9	2.5

B. Overlay Registration Test – Tool Induced Shift:

The system Tool Induced Shift (TIS) performance shall be demonstrated on the wafers from Section II.A.

Test Procedure: This test shall include measuring ten box-in-box overlay registration marks at agreed to locations across the wafer described. Ten static mode measurements for each site shall be taken. This test shall be run after IVS has performed the RG180 calibration process. TIS shall be calculated as follows: ((reg. measurement means for x, y axes with the notch or flat at 0 degrees) + (reg. measurement means for x, y axes with the **notch or** flat at 180 degrees))/2.

Specification: Mean Value of TIS (for both x and y axis) $\leq \pm 2$ nanometers
Worst Case Value of TIS (for both x and y axis) $\leq \pm 5$ nanometers

It should be noted that system performance may be affected by: extremely grainy films, targets distorted by CMP, film thickness variations and edge slope variations more than +/-10% in the targeted measurement area.

SLOT	WAFER ID	X AXIS TIS Average In nm	Y AXIS TIS Average In nm	SPEC. In nm
1	APSC N/10vs5/rg	0.2	0.3	± 2.00
3	HIMQ N/180vs160/rg	-0.9	0.2	± 2.00
5	CECF N/60vs90/rg	0.2	0.2	± 2.00
7	CECF N/140vs130/rg	0.6	0.7	± 2.00

C. Critical Dimension Test - Precision

The precision of the system CD performance shall be demonstrated on four standard production layers as described below. One mutually acceptable wafer shall be provided for each of the four CD test layers defined. This specification addresses the 100x lens. Specifications for measurements using the 5x, 20x, 50, and 150x lenses will be quoted upon request.

Test Procedure: This test shall include measuring an agreed to nominal greater than or equal to 1.0 micron line at five CD sites across the wafers described. Ten dynamic mode measurements (wafer load/unload between measurements) for each site shall be taken.

Specification: Pooled 3 Sigma Standard Deviation ≤ 12 nanometers, or 1%, whichever is greater.

SOLURIS

SLOT	WAFER ID	POOLED 3σ in nm	SPEC. 3σ in nm
19	J454_O/125/CD	5.0	13.9
21	CORA_O/160M/CD	1.9	12.0
23	AGDA_N/9/CD	11.8	12.0
25	CORA_O/160R/CD	8.4	14.3

D. Pitch – Accuracy and Precision

The accuracy and precision of the tool shall be demonstrated on at least 1 VLSI wafer. Pitch measurements shall be made on 2 and 4 μm targets.

Test Procedure: This test shall include measuring a VLSI certified pitch standard. The 2.0 and 4.0 μm pitch targets shall be measured ten times dynamically, and their mean and precision values shall be taken.

SLOT	WAFER ID	PITCH in μm	POOLED 3σ in nm
16	LWS-2640 2 μm	2.0011	2.5
16	LWS-2640 4 μm	3.9989	4.2

III. Focus and Pattern Recognition:

The IVS 130 shall be able to focus and perform the pattern recognition function successfully 98% of the time on the production wafer layers defined in Section II.A and II.C. If a failure occurs, the system must continue to process wafers unassisted. A failure will result with a focus or pattern recognition system error code in the data. No wafers with known pattern defects shall be used in the testing.

SLOT	WAFER ID	NUMBER OF SITE LOCATES	PATTERN RECOGNITION (percent)	SPEC. (percent)
1	APSC_N/10vs5/rg	10	100.0	98.0
3	HIMQ_N/180vs160/rg	10	100.0	98.0
5	CECF_N/60vs90/rg	10	100.0	98.0
7	CECF_N/140vs130/rg	10	100.0	98.0
19	J454_O/125/CD	5	100.0	98.0
21	CORA_O/160M/CD	5	100.0	98.0
23	AGDA_N/9/CD	5	100.0	98.0
25	CORA_O/160R/CD	5	100.0	98.0

IV. System Throughput Test:

A. Throughput Test - 5 die/wafer; 1 site/die:

System throughput shall include measuring one registration feature in the x and y axes

SOLURIS

at each of five sites per wafer. The test will measure one layer type and will use a single job. IVS' Edge Focus method along with the grey scale pattern recognition method shall be used. System throughput shall be measured starting at the beginning of the vacuum sensing of the first wafer on the stage and ending with the tenth wafer from the stage at vacuum sense off. In the event that 10 wafers are not provided, one wafer shall be measured 10 times, and throughput shall be measured starting at the beginning of the vacuum sensing of the wafer on the stage and ending when the wafer is taken from the stage and the vacuum sensing turns off.

Specification: The system shall measure 90 wafers per hour performed on ten wafers using one of the standard production layers identified in section II.A.

RUN	WAFER ID	Wafer Time In Sec.	Throughput In WPH	SPEC. In WPH
1		39	92.3	
2		40	90.0	
3		39	92.3	
4		38	94.7	
5		40	90.0	
6		39	92.3	
7		41	87.8	
8		40	90.0	
9		40	90.0	
10		40	90.0	
Average:			90.9	90

V. Particle Count:

The IVS 130 shall not add more than 10 particles, per pass per eight inch wafer, 0.1 microns in size or larger. Five test wafers and five control wafers shall be measured for particulates before the test. The test wafers shall: transfer from the cassette to the flat finder; transfer the wafer to the stage; rotate objectives; and then be replaced in the cassette. The control wafers shall be set on top of the IVS 130 to establish a background particulate level. This procedure shall be repeated five times for each wafer. The test and control wafers shall be particulate tested after completion of the ten passes. The environment around the system shall be isolated and/or be controlled for this test.

SOLURIS

Particles per wafer, per pass, shall defined as:

$PWP = W \times n \times (PG_{test} - PG_{control}) = 5 \times 5 \times 2 = -50$
PWP = Particles per Wafer per Pass
W = Number of wafers measured
n = Number of passes through the system
PG = (Particles measured after the test) - (Particles measured before the test)

It is expected that the particle test will be run within a reasonable period of time in comparison to when the rest of the system acceptance tests are run.

SLOT	WAFER ID	PARTICLE BEFORE TEST	PARTICLE AFTER TEST	Delta	SPEC. (Particles)
1	Sample	1	1	0	≤10.0
2	Control	6	7	1	
3	Sample	0	0	0	≤10.0
4	Control	12	12	0	
5	Sample	2	2	0	≤10.0
6	Control	3	4	1	
7	Sample	1	1	0	≤10.0
8	Control	6	8	2	
9	Sample	8	6	-2	≤10.0
10	Control	5	6	1	

VI. Software

The system software will operate according to the description in the User's Manual. Any software releases will be accompanied by a set of Release Notes which will detail the changes to the system software and operations. This documentation will be provided in a format similar to the User's Manual which will allow for the material to be added as an addendum to the manual.

In the event the optional GEM communications package is purchased, the package shall function as described in the SEMI E30-94 document excluding the limits monitoring capability. Soluris will quote modifications to this package upon request.

In the event the optional SECS II communications package is purchased, the package shall function in accordance with Soluris' specifications.

In the event the Metroboost Overlay Booster Stepper Optimization Package is purchased, the package shall provide the functionality associated with v2.38 and higher, and will be in

SOLURIS

accordance with the Overlay Booster User Guide. Soluris will quote additions and modifications to this package upon request.

In the event the optional Monolith Stepper Analysis package is purchased with real-time capability, the package shall function in accordance with the NVS Monolith manual. Soluris will quote additions and modifications to this package upon request.

VII. Miscellaneous:

The above acceptance test specification is subject to Soluris' pre-examination of the wafers that will be used for this test. It should be noted that system performance may be affected by: extremely grainy films, film thickness variations and edge slope variations more than +/-10% in the targeted measurement area. After Soluris has reviewed the wafers submitted for the Acceptance Test, a final commitment will be made concerning the actual system performance specifications.

The system shall be considered accepted by **AMIS**, and warranty shall begin: 1. After successful completion of the agreed-to acceptance test, and sign-off by **AMIS** OR upon beneficial use by **AMIS**. Beneficial use is defined as using the system for something other than testing, including but not limited to pilot production, engineering test lots, production, and device prototyping. In cases where the facility and/or utilities are not ready as committed by customer, customer is liable for revisit expenses.

The equipment shall be available and fully operational 95% of the time. A call reporting that the equipment is down must be made to Soluris before system down time can begin. Soluris Customer Service provides on-site technical support during normal business hours, which are Monday through Friday, 8:30 am to 5:30 PM local time (exclusive of Soluris Holidays) during the Warranty period. Soluris also provides Answering Service support 7 days per week, 24 hours per day. This service will route your incoming calls accordingly. Wafers for the above tests shall be provided to Soluris as soon as possible although no later than six weeks prior to the scheduled shipment date. These wafers shall be used for the factory acceptance and the final acceptance testing at the customer facility.

SOLURIS

VIII. System Factory Acceptance Testing

The IVS 130 has successfully demonstrated the capability expected by the customer for Source Acceptance. Shipment from Soluris is authorized.

Marc Poulingue
Applications Engineer
Soluris Inc.

Feb. 27, 2004

Date

Leo Schlegel
Sr. Process Engineer
AMI Semiconductor Belgium BVBA

Feb. 27, 2004

Date

Measurement System analysis Data Sheet

Measurement System : IVS Date : 25-Feb-04 Performed by : Soluris

Measurement Program : APSCN/010/OVERLAY - Y direction

Operation number : nwell I2T LSL : -0.3 USL : 0.3

operator	A				B				C			
Sample	T1	T2	T3	R	T1	T2	T3	R	T1	T2	T3	R
1	-0.0066	-0.0064	-0.0058	0.0008	-0.0049	-0.0044	-0.0042	0.0007	-0.0062	-0.0072	-0.0065	0.001
2	0.0193	0.0177	0.0176	0.0017	0.0194	0.0204	0.0195	0.001	0.0191	0.0191	0.0177	0.0014
3	-0.0043	-0.0055	-0.0075	0.0032	-0.005	-0.0049	-0.0055	0.0006	-0.0056	-0.0054	-0.0068	0.0014
4	0.0013	-0.0008	-0.0002	0.0021	0.0013	0.0006	-0.0004	0.0017	0.0026	-0.0012	-0.0003	0.0038
5	-0.0032	-0.0035	-0.0057	0.0025	-0.0036	-0.0063	-0.0031	0.0032	-0.0062	-0.0046	-0.005	0.0016
6	-0.0113	-0.0088	-0.0088	0.0025	-0.0091	-0.0068	-0.0085	0.0023	-0.008	-0.0084	-0.0081	0.0004
7	-0.0005	-0.0016	-0.0011	0.0011	-0.0032	-0.0017	-0.0019	0.0015	-0.0026	-0.0015	-0.0005	0.0021
8	0.0148	0.0126	0.0158	0.0032	0.0129	0.0141	0.0139	0.0012	0.015	0.0144	0.0138	0.0012
9	0.0211	0.0213	0.0224	0.0013	0.0206	0.0226	0.0234	0.0028	0.021	0.0203	0.0225	0.0022
10	-0.0014	0.0005	-0.0013	0.0019	-0.0006	-0.0012	-0.0004	0.0008	-0.0022	-0.0022	0.0009	0.0031
11				0				0				0
12				0				0				0
13				0				0				0
14				0				0				0
15				0				0				0

Totals	0.029	0.026	0.025	0.020	0.028	0.032	0.033	0.016	0.027	0.023	0.028	0.018
N	10			N	10			N	10			
Trials	2			Oper.	3							

T1	0.029
T2	0.026
T3	0.025
SUM	0.080
Xav	0.003
Rav	0.002

T1	0.028
T2	0.032
T3	0.033
SUM	0.093
Xav	0.003
Rav	0.002

T1	0.027
T2	0.023
T3	0.028
SUM	0.078
Xav	0.003
Rav	0.002

Raverage	0.002
UCLrange	0.006

d ₂	1.128
D2s	1.910
D4	3.267

Xmax	0.003	
Xmin	0.003	
Xdelta	0.001	0.000

Repeatability : 0.010

Variation in measurement when one operator uses the same instrument and measures the same parts

Reproducibility : 0.000

Variation in measurement due to different operators or instruments, measuring the same parts

R&R : 0.010

Total variation due to repeatability and reproducibility

R&R % : 1.60

Percent of the tolerance that is taken up by measurement error